J.R. Holzmacher P.E., LLC

3555 Veterans Memorial Highway Suite A, Ronkonkoma New York 11779 Tel: (631) 234-2220 Fax: (631) 234-2221 e-mail: info@holzmacher.com

INC. VILLAGE OF NORTHPORT NORTHPORT COW HARBOR PARK BASKETBALL COURT & LANDSCAPE IMPROVEMENT BID #2023-01

ADDENDUM - 1

To: Bidders list

CC: Inc. Village of Northport From: J.R. Holzmacher P.E., LLC

Date: January 27, 2023 Bid Date: January 31, 2023

This Addendum No. 1 contains Bidders' questions and official answers.

Question 1: Please confirm location of electrical panel to supply bollard and bench lighting.

Answer: Bollard and bench lighting supply to run through underground

conduit to adjacent restroom structure. Conduit to run up and penetrate through exterior wall to existing panel inside. Penetration to

be weather sealed as required.

Question 2: What type of conduit material will be required? Is there a circuiting plan or riser

diagram for the lighting?

Answer: Please see "Section 16134 – Conduit" of the spec book for information

on PVC coated rigid hot dripped galvanized steel conduits to be used for the bollard and bench lighting. There is no circuit plan or riser

diagram for this scope of work.

INCORPORATED VILLAGE OF NORTHPORT NORTHPORT COW HARBOR PARK BASKETBALL COURT & LANDSCAPE IMPROVEMENT Bidder Questions and Answers January 27, 2023 Page 2

END OF ADDENDUM No.1

Very truly yours,

J.R. Holzmacher P.E., LLC

Thomas Murawski Registered Architect Director

TM:kf

CC: Donna Koch, Inc. Village of Northport, Village Mayor Donald Tesoriero, Inc. Village of Northport, Asst. to the Mayor/NYSCEO